

Office of Civil Surgeon, Kurukshetra

No. GH/2023/ 1310

Date: 07/06/23


SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Senior Medical Officer, CHC Ladwa, Kurukshetra from Health Department inspected the building of K B Scholars School, Ladwa Road, Kurukshetra on 02-06-2023 and found that the facilities for the students and members of staff of the institution is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt. The above is valid for a period of **One year from the date of issue.**

Signature with seal :
Name : Dy. Civil Surgeon (Health)
Kurukshetra
Designation : Dy. Civil Surgeon, Kurukshetra
Name & Address of the office/Department:
O/o Civil Surgeon, Kurukshetra

To
Principal,
K B Scholars School, Ladwa Road,
Kurukshetra.


Principal
K B Scholars School
Ladwa (Kurukshetra)


Director
K B Scholars School
Pipli Road, Ladwa (KKR)-136132





Govt. of Haryana

Public Health Engineering Department, Water Testing Laboratory, Kurukshetra

Email id:-chemist.kkra@gmail.com

Test Report


URL No. : TC45602300000295F	Sample Collected on Date : 15/05/2023
Test Report No.: KKR/00748/05/2023	Sample Received on Date : 15/05/2023
Sender : PRINCIPAL, K.B. SCHOLARS SCHOOL, LADWA (ON ROAD NR. VILL. NIWARS), KURUKSHETRA.	Sample Location : T/Well K.B. SCHOLARS SCHOOL, LADWA (ON ROAD NR. VILL. NIWARS), KKR,
Customer Reference No. : 0	Sample Quantity : 1 Ltr.
Sample Description : Water	Date of Analysis Started : 15/05/2023
Sample Type : Physico-Chemical Analysis	Date of Analysis Completed : 17/05/2023
Memo No. : 617 Date: 17/05/2023	Date of issue : 17/05/2023


S.No.	Parameter	Protocol used	Result	IS:10500:2012(Second revision)		Unit
				Acceptable Limit	Permissible limit in the absence of alternate source	
1	Colour	IS 3025(Part-4): 1983 (RA 2017)	05	5	15	Hazen
2	Odour	IS 3025(Part-5): 1984 (RA 2018)	Agreeable	Agreeable	Agreeable	-
3	Taste	IS 3025(Part-8): 1984 (RA 2017)	Agreeable	Agreeable	Agreeable	-
4	Total Dissolve Solids	IS 3025(Part-16): 1984 (RA 2017)/ APHA2540C	319	500	2000	mg/L
5	Total Hardness	IS 3025(Part-21): 2009 (RA 2019)/ APHA2340C	171.50	200	600	mg/L
6	Calcium (as Ca)	IS 3025(Part-40): 1991 (RA 2019)/ APHA3500-Ca B	41.23	75	200	mg/L
7	Magnesium (as Mg)	IS 3025(Part-46): 1994 (RA 2019)/ APHA3500-Mg B	16.70	30	100	mg/L
8	Total Alkalinity	IS 3025(Part-23): 1986 (RA 2019)/ APHA2320 B	290.0	200	600	mg/L
9	Chloride (as Cl)	IS 3025(Part-32): 1988 (RA 2019)/ APHA4500-Cl B	28.92	250	1000	mg/L
10	Sulphate (as So4)	IS 3025(Part-24): 1986 (RA 2019)/ APHA4500-So4 E	---	200	400	mg/L
11	Fluoride (as F)	APHA4500-F C	0.01	1.0	1.5	mg/L
12	Iron (as Fe)	IS 3025(Part-53): 2003 (RA 2019)/ APHA3500-Fe B	0.10	1.0	No Relaxation	mg/L
13	Nitrate(as NO3)	APHA 4500-NO3D	0.60	45	No Relaxation	mg/L
14	PH	IS 3025(Part-11): 1983 (RA 2022)/ APHA4500-H B	8.16	6.5 to 8.5	No Relaxation	-
15	Turbidity	IS 3025(Part-10): 1998 (RA 2022)/ APHA2130 B	BDL	1	5	NTU

Notes:

- 1 The results given above are related to the sample as received and tested in PHED Lab, Kurukshetra. Reliability of sample lies with the sender.
- 2 The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- 3 The test report can't be used for any publicity or any legal purpose.
- 4 The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.


Director
K B Scholars School
Pipli Road, Ladwa (KKR)-136132


(Nisha Saini)
Chemist
Public Health Engg. Department
Water Testing Lab, Kurukshetra


Principal
K B Scholars School
Ladwa (Kurukshetra)



PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, KURUKSHETRA

Website :- <https://phedharyana.gov.in/>

Memo No:- 619

Date:- 17/05/2023

Subject : Bacteriological Examination Report of Water Sample

Sample ID: KKR/00749/5/2023		Sample Details	Date & Time
Sample Classification: Private		Collected By	,9813848071
Sender: Principal KB scholars school ladwa21097		Collection Date	15/05/2023 at 10:39
Location :- , On road ladwapiple road niwarsi		Received at lab	15/05/2023 at 14:55
Latitude :- 77.045101 Longitude :- 30.066344		Tested at Lab	17/05/2023

Test Result (As Per BIS 10500 :2012)


S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in KURUKSHETRA lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"




NISHA SAINI, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY, KURUKSHETRA
email:-chemist.kkra@phedharyana.gov.in

—End of Report—


Principal
K B Scholars School
Ladwa (Kurukshetra)


Director
K B Scholars School
Pipli Road, Ladwa (KKR)-136132

